



Branch 0300 – Pilsen

# CERTIFICATE

No. 030 – 054184

## about the qualities of a product

**Certified quality:** **SLIPPERINESS**  
according to the following test procedures:

**DIN 51097** Testing of floor coverings – Determination of the anti-slip properties – wet-loaded barefoot areas – walking method – ramp test

**Product:** CC-PU – Siegel-Antislip

**Producer:** CC-Dr. Schutz GmbH, Holbeinstrasse 17, 531 75 Bonn, Germany

**Order:** Z 030160418

**Achieved values and recommended use:**

<b>Slipperiness of CC-PU – Siegel-Antislip:</b>	<b>DIN 51097 (barefoot) classification</b>
	<b>25,4° class C</b>

The certificate is issued on the basis of the results of the tests stated in report no. 030–045026 (same technology according the manufacturer).

Number of pages of certificate: 1

Certificate validity: **till 31 December 2017**

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.

Pilsen 7<sup>th</sup> December 2016



Stamp of T.ZÚS + branch Pilsen

**Ing. Alexander Trinner**  
Branch Director

**Warning:** Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.